




NOTES

1. Type C ramps are only to be used to mitigate conditions where inadequate right-of-way exists. Type C shall only be used with the approval of the City Engineer.
2. See Standard Drawing CVCS-29 for general notes.
3. Landing cross slope and longitudinal slope shall be 2% max.
4. For truncated domes, please see CVCS-29.
5. CT Curve Transition slope shall be 8.33% maximum.

Revised:	Original approval date: 3-13-94	CITY OF CHULA VISTA	
12/8/05	Redrawn By: CVM	Date: 12-2-05	PUBLIC WORKS DEPARTMENT
			CVCS
			27A
	CITY ENGINEER Date: 12/5/05		CURB RAMP - TYPE C



PLAN




SECTION A-A

NOTES

1. Type C ramps are only to be used to mitigate conditions where inadequate right-of-way exists. Type C shall only be used with the approval of the City Engineer.
2. See CVCS-29 for General Notes.
3. Landing cross slope and longitudinal slope shall be 2% maximum.
4. For truncated domes, please see CVCS-29.
5. CT Curve Transition slope shall be 8.33% maximum.

NOT TO SCALE

Revised:	Original approval date: 3-13-94	CITY OF CHULA VISTA PUBLIC WORKS DEPARTMENT	
12/8/05	Redrawn By: CVM Date: 8-21-05		
		PEDESTRIAN RAMP DETAIL TYPE "C" MODIFIED	CVCS 27B
	CITY ENGINEER Date: 12/8/05		